

Satellite Accumulation Area (SAA) Inspection Form			
Date:		Time:	
Command:		Bldg. Location:	
POC:		Telephone #:	
Inspector's Name:		Signature:	
INSPECTION ITEMS	YES	NO	COMMENTS
1. Are containers in good condition with no or minimal dents or corrosion?			
2. Are containers labeled Hazardous Waste or with other words identifying contents?			
3. When quantity of waste reaches 55 gallons, is waste transferred to the Less-than-90-day Storage Facility within 72 hours?			
4. Are containers properly closed?			
5. Is the Satellite Accumulation Area located at or near the point of generation?			
6. Is the hazardous accumulation limited to less than 55-gallon (or 1 quart Acute) of total accumulated hazardous waste?			
7. Is the 2-inch expansion rule in liquid containers complied with?			
8. Are accumulation/fill dates marked once 55-gallon limit is reached?			
9. Is waste compatible with the container?			
10. Are incompatible wastes kept separate?			
11. Is proper isle space maintained?			
12. Is the SAA clean (no signs of spillage) and are containers non-leaking?			
13. Are liquid waste containers placed in a berm area, or an area which will contain all leaks?			
14. Is a fire extinguisher available within 50 ft.?			
15. Is housekeeping neat and clean in all areas?			
16. Is there a spill kit in the accumulation area?			
17. Are containers inspected weekly?			
18. Does the assigned Hazardous Waste Coordinator and Alternate have proper training?			
19. Are training records maintained for three years?			
Comments:			